

...CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-1130:169 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Honeywell International Inc., 1500 W. Dundee Rd., Arlington Heights, IL 60004-1472
Contact: Bob Hodgson (847) 797-4403 FAX (847) 797-3664

DESIGN: Models XLS202-3A-T, XLS202-5A-T, XLS202-7A-T, XLS202-8A-T; XLS405-3A-T, XLS405-5A-T, XLS405-7A-T and XLS405-8A-T strobe lights. Unit may be followed by suffix -B, -R or -W to indicate product color. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Candela: -5A: 15cd
-3A: 30cd
-7A: 15/75cd
-8A: 110cd

Electrical: 20-24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, candela/electrical rating, and UL label.

APPROVAL: Listed as strobe lights suitable for the hearing impaired when used in conjunction with separately listed electrically and functionally compatible fire alarm control units. *Models with a candela rating of 15cd are for indoor use only. *All other models are designed for indoor and outdoor use. Refer to listee's Installation Instruction Manual for details.

NOTE: If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal.

XLF: *7125-1591:184 Formerly 7125-1388:208

*Rev. 03-30-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**